

**Materialprüfungsamt Nordrhein-Westfalen**

Prüfen • Überwachen • Zertifizieren

**Certificate of conformity of the factory production control  
0432-CPR-21 8850 (EN)**

Version 03

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

**connecting flue pipes****made of steel: S235 JRG 2/ DC01/ DD11**

(for a detailed product description see annex 1 of this certificate)

placed on the market under the name or trade mark of

**STAHL SYSTEM Janusz Graniczka**

Chorzelów 223

39 - 331 Chorzelów, Polen

and produced in the manufacturing plant(s)

**STAHL SYSTEM Janusz Graniczka**

Sadkowa Góra 103

39 – 305 Borowa, Polen

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 1856-2:2009**

under **system 2+** are applied and that

**the factory production control is assessed to be in conformity  
with the applicable requirements**

This certificate was first issued on 16.02.2012 and will remain valid until 03.11.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 04.11.2022

by order

Thorsten Frank (M. Sc.)  
Head of Certification Body (Dept. 21)

This Certificate consists of 1 page and 1 annex(es).

This Certificate replaces the Certificate no. 0432-CPR-218850  
dated 09.05.2018, Version 02.

The original of this document was issued in German language.  
In case of doubt only the German version is valid.





Vom Hersteller erklärte Eigenschaften für / *Declared conditions by the manufacturer for:*

	Art der Abgasanlage/ Leitung <i>type of chimney/ flue pipe</i>	Harmonisierte Norm <i>standard</i>	Produktbeschreibung <i>Product description</i>
01	Verbindungsstücke/ <i>connecting flue pipes</i>  Rohr/ <i>pipe</i> : S235 JRG 2/ DC01/ DD11 Wanddicke/ <i>wall thickness</i> : 1,5 - 2,0 mm (-10 %)	EN 1856-2:2009	T600 – N2 – D – Vm – L01200 – G(300)M T600 – N2 – D – Vm – L01150 – G(300)M  DN120 – DN300  Abstand zu brennbaren Bauteilen/ <i>distance to combustibles</i> : 300 mm

